

Intermittent Fault Detection & Isolation System 2.0[™] (IFDIS 2.0[™])





Prepared and Submitted by:

Universal Synaptics 4066 S 1900 W Ste B Roy, Utah 84067 801.731.8508

COMMERCIAL-IN-CONFIDENCE

Universal Synaptics Corporation (USC) owns the copyright in this document. It cannot be used for any purpose other than that for which it is supplied nor reproduced or copied, in whole or in part. It is Commercial-in-Confidence and is not to be communicated to any person without written consent from USC.



Weapon Replaceable Assembly (WRA) 7

Introduction:

Universal Synaptics requested and received an EA-18G WRA 7 "gold unit" asset from to build an Interface Test Adapter (ITA) to electrically connect to the Intermittent Fault Detection & Isolation System 2.0 (IFDIS 2.0) and automatically generate the Test Program Set (TPS) through AutoMap[™]. The WRA 7 asset arrived with a Serviceable Tag marked Condition Code A ("gold unit") – Ready for Install (RFI) – see Photo A and B.



Photo A - WRA 7 with Service Tag Condition Code A

WARNING: Unauthorized persons removing, defacing, or destroying this label may be subject to a fine of not more than 51,000 or imprisonment for not more than one year or both. (18 USC 1361)	FSN, PART NO AND ITEM DESCRIPTION 5841-01.624-0932 117K060G03 WRAT WIFED CLASS SERIAL NUMBERVILOT NUMBER 1094 CONTRACT OR PURCHASE ORDER NO NA REMARKS RILOP	IS UNIT OF ISSUE LEA QUANTITY DI	SERVICEABLE TAGA NEXT INSPECTION DUE/OVER AGE DATE MA INSPECTION ACTIVITY INSPECTOR'S NAME OR STAMP AN 1/5/17	CODE	Previous addition
or the V					

Photo B - Service Tag Condition Code A




Test Procedures:

Universal Synaptics' technical team began validating form and fit of WRA 7 ITA using IFDIS 2.0 on 17 April 2019. At the conclusion of form and fit validation, AutoMap[™] was performed and the TPS was automatically generated. TPS validation consisted of Continuity Test, Shorts Test, and Intermittence Test.


Results:

- 1. Continuity testing was conducted, and no open circuits were found in the WRA.
- 2. Shorts testing was conducted, and no shorted circuits were found in the WRA.
- 3. Intermittence testing was conducted with light tapping and minor manual manipulation. One circuit experienced 28 intermittent events.
 - a. Location of Detected and Isolated Intermittent Fault: J2-056, Test Point (TP) 2978, connected to Node 1143 see Graphic 1 *Column View* and Graphic 2 Graphical XY Coordinate (*GXY*) *View*.



Graphic 1 - Fault Isolation Graphic – WRA 7 Column View





Graphic 2 - Fault Isolation Graphic - WRA 7 GXY View

Summary:

With only minor manual manipulation, this RFI Condition Code A asset, had an intermittent fault, detected and isolated by IFDIS 2.0. Universal Synaptics recommends full IFDIS 2.0 testing under simulated operational environment conditions, using a temperature and vibration, as additional intermittent faults may be present in this asset.

Summary Video: WRA 7 Intermittent Clip

Additional Information:

Website: <u>www.usynaptics.com</u>, <u>www.nofaultfound.com</u> Video: <u>Intermittent Fault Detector</u> Email: <u>contact@usynaptics.com</u> Phone: 801.731.8508